



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

July 3, 2008

Mr. Gerardo Rios
Chief, Permits Office
U.S. EPA – Region IX – Air – 3
75 Hawthorne Street
San Francisco, CA 94105

Subject: Title V Permit to Operate Revision

Dear Mr. Rios:

The University of California, Los Angeles (ID #18452) has proposed to revise their Title V facility permit by adding an emergency internal combustion engine, A/N 481972. This proposed revision is considered a "de minimis significant permit revision" to their Title V Facility Permit. Attached for your review is the draft Title V permit for the proposed revision. With your receipt of this proposed Title V permit, we will note that the EPA 45-day review period has begun.

If you have any questions or wish to provide comments regarding these changes, please call the processing engineer, Ms. Maria Vibal at (909) 396-2422.

Sincerely,

Michael D. Mills

Michael D. Mills, P.E.
Senior Manager
General Commercial and Energy Team
Engineering and Compliance

MDM:MYL:RGC:MV

Enclosures

cc: (w/o Enclosures)
Title V Facility File
Title V Admin File

Cloning the old permit for 2008

FACILITY PERMIT TO OPERATE

UNIVERSITY OF CALIFORNIA, LOS ANGELES

APPENDIX B: RULE EMISSION LIMITS [RULE 1107 1-6-2006]

Except as otherwise provided in Rule 1107

(1) VOC Content of Coatings

A person shall not apply to metal parts and products subject to the provisions of this rule any coatings, including any VOC-containing materials added to the original coating supplied by the manufacturer, which contain VOC in excess of the limits specified below:

VOC LIMITS Less Water and Less Exempt Compounds Effective Dates								
Coating	Air-Dried				Baked			
	gm/l		lb/gal		gm/l		lb/gal	
	Current	7/1/07	Current	7/1/07	Current	7/1/07	Current	7/1/07
General One-Component	275	275	2.3	2.3	275	275	2.3	2.3
General Multi-Component	340	340	2.8	2.8	275	275	2.3	2.3
Military Specification	340	340	2.8	2.8	275	275	2.3	2.3
Etching Filler	420	420	3.5	3.5	420	420	3.5	3.5
Solar-Absorbent	420	420	3.5	3.5	360	360	3.0	3.0
Heat-Resistant	420	420	3.5	3.5	360	360	3.0	3.0
Extreme High-Gloss	420	340	3.5	2.8	360	360	3.0	3.0
Metallic	420	420	3.5	3.5	420	420	3.5	3.5

FACILITY PERMIT TO OPERATE

UNIVERSITY OF CALIFORNIA, LOS ANGELES

APPENDIX B: RULE EMISSION LIMITS [RULE 1107 1-6-2006]

VOC LIMITS								
Less Water and Less Exempt Compounds								
Effective Dates, cont.								
Coating	Air-Dried				Baked			
	gm/l		lb/gal		gm/l		lb/gal	
	Current	7/1/07	Current	7/1/07	Current	7/1/07	Current	7/1/07
Extreme Performance	420	420	3.5	3.5	360	360	3.0	3.0
Prefabricated Architectural One-Component	420	275	3.5	2.3	275	275	2.3	2.3
Prefabricated Architectural Multi-Component	420	340	3.5	2.8	275	275	2.3	2.3
Touch Up	420	420	3.5	3.5	360	360	3.0	3.0
Repair	420	420	3.5	3.5	360	360	3.0	3.0
Silicone Release	420	420	3.5	3.5	420	420	3.5	3.5
High-Performance Architectural	420	420	3.5	3.5	420	420	3.5	3.5
Camouflage	420	420	3.5	3.5	420	420	3.5	3.5
Vacuum-Metalizing	420	420	3.5	3.5	420	420	3.5	3.5
Mold-Seal	420	420	3.5	3.5	420	420	3.5	3.5
High-Temperature	420	420	3.5	3.5	420	420	3.5	3.5
Electric-Insulating Varnish	420	420	3.5	3.5	420	420	3.5	3.5
Pan Backing	420	420	3.5	3.5	420	420	3.5	3.5
Pretreatment Coatings	420	420	3.5	3.5	420	420	3.5	3.5

- (2) A person shall not use VOC-containing materials which have a VOC content of more than 200 grams per liter of material for stripping any coating governed by this rule.

FACILITY PERMIT TO OPERATE

UNIVERSITY OF CALIFORNIA, LOS ANGELES

APPENDIX B: RULE EMISSION LIMITS [RULE 1107 11-9-2001]

Except as otherwise provided in Rule 1107

(1) VOC Content of Coatings

A person shall not apply to metal parts and products subject to the provisions of this rule any coatings, including any VOC-containing materials added to the original coating supplied by the manufacturer, which contain VOC in excess of the limits specified below:

LIMITS				
Grams of VOC Per Liter of Coating, Less Water and Less Exempt Compounds				
<u>Coating</u>	<u>Air Dried</u>	<u>(lb/gal)</u>	<u>Baked</u>	<u>(lb/gal)</u>
General				
One-Component	275	(2.3)	275	(2.3)
Multi-Component	340	(2.8)	275	(2.3)
Military Specification	340	(2.8)	275	(2.3)
Etching Filler	420	(3.5)	420	(3.5)
Solar-Absorbent	420	(3.5)	360	(3.0)
Heat-Resistant	420	(3.5)	360	(3.0)
Extreme High-Gloss	420	(3.5)	360	(3.0)
Metallic	420	(3.5)	420	(3.5)
Extreme Performance	420	(3.5)	360	(3.0)
Prefabricated Architectural Component	420	(3.5)	275	(2.3)
Touch Up	420	(3.5)	360	(3.0)
Repair	420	(3.5)	360	(3.0)
Silicone Release	420	(3.5)	420	(3.5)
High Performance Architectural	420	(3.5)	420	(3.5)
Camouflage	420	(3.5)	420	(3.5)
Vacuum-Metalizing	420	(3.5)	420	(3.5)
Mold-Seal	420	(3.5)	420	(3.5)
High-Temperature	420	(3.5)	420	(3.5)
Electric-Insulating Varnish	420	(3.5)	420	(3.5)
Pan Backing	420	(3.5)	420	(3.5)
Pretreatment Coatings	420	(3.5)	420	(3.5)

FACILITY PERMIT TO OPERATE
UNIVERSITY OF CALIFORNIA, LOS ANGELES

APPENDIX B: RULE EMISSION LIMITS
[RULE 1107 11-9-2001]

- (2) A person shall not use VOC-containing materials which have a VOC content of more than 200 grams per liter of material for stripping any coating governed by this rule.

FACILITY PERMIT TO OPERATE

UNIVERSITY OF CALIFORNIA, LOS ANGELES

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 11-8-1996]

- (1) Except as provided in paragraphs (c)(2), (c)(3), and (c)(4) of Rule 1113, the operator shall not supply, sell, offer for sale, apply, or solicit the application of; any architectural coating which, at the time of sale or manufacture, contains more than 250 grams of VOC per liter of coating (2.08 pounds per gallon), less water, less exempt compounds, and less any colorant added to tint bases, or manufacture, blend, or repackage such a coating for use within the District.
- (2) Except as provided in paragraphs (c)(3) and (c)(4) of Rule 1113, the operator shall not supply, sell, offer for sale, apply, solicit the application of, manufacture, blend, or repackage, for use within the District, any architectural coating listed in the Table of Standards which contains VOC (excluding any colorant added to tint bases) in excess of the corresponding VOC limit specified in the table, after the effective date specified.

TABLE OF STANDARDS

VOC LIMITS

**Grams of VOC Per Liter of Coating,
 Less Water And Less Exempt Compounds**

COATING	Limit*	Effective Date of Adoption	Effective 1/1/1998	Effective 1/1/1999	Effective 7/1/2001	Effective 1/1/2005	Effective 7/1/2008
Bond Breakers	350						
Clear Wood Finishes							
Varnish	350						
Sanding Sealers	350						
Lacquer	680		550			275	
Concrete-Curing Compounds	350						
Dry-Fog Coatings	400						
Fire-proofing Exterior	350	450		350			
Coatings							
Fire-Retardant Coatings							
Clear	650						
Pigmented	350						
Flats	250					100	
Graphic Arts (Sign) Coatings	500						50
Industrial Maintenance							

FACILITY PERMIT TO OPERATE

UNIVERSITY OF CALIFORNIA, LOS ANGELES

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 11-8-1996]

Primers and Topcoats						
Alkyds	420					
Catalyzed Epoxy	420					
Bituminous Coatings	420					
Materials						
Inorganic Polymers	420					
Vinyl Chloride Polymers	420					
Chlorinated Rubber	420					
Acrylic Polymers	420					
Urethane Polymers	420					
Silicones	420					
Unique Vehicles	420					
Japans/Faux Finishing	350	700		350		
Coatings						
Magnesite Cement Coatings	600			450		
Mastic Coatings	300					
Metallic Pigmented Coatings	500					
Multi-Color Coatings	420		250			
Pigmented Lacquer	680		550			275
Pre-Treatment Wash Primers	780					
Primers, Sealers, and	350					
Undercoaters						
Quick-Dry Enamels	400					
Roof Coatings	300					
Shellac						
Clear	730					
Pigmented	550					
Stains	350					
Swimming Pool Coatings						
Repair	650					
Other	340					
Traffic Coatings	250		150			
Waterproofing Sealers	400					
Wood Preservatives						
Below-Ground	350					
Other	350					

* The specified limits remain in effect unless revised limits are listed in subsequent columns in the Table of Standards

FACILITY PERMIT TO OPERATE
UNIVERSITY OF CALIFORNIA, LOS ANGELES

APPENDIX B: RULE EMISSION LIMITS
[RULE 1113 11-8-1996]

TABLE OF STANDARDS (cont.)

VOC LIMITS

Grams of VOC Per Liter of Material

COATING	Limit
Low-Solids Coating	120

FACILITY PERMIT TO OPERATE

UNIVERSITY OF CALIFORNIA, LOS ANGELES

APPENDIX B: RULE EMISSION LIMITS **[RULE 1113 7-13-2007]**

- (1) Except as provided in paragraphs (c)(2), (c)(3), (c)(4), and specified coatings averaged under (c)(6), no person shall supply, sell, offer for sale, manufacture, blend, or repackage any architectural coating for use in the District which, at the time of sale or manufacture, contains more than 250 grams of VOC per liter of coating (2.08 pounds per gallon), less water, less exempt compounds, and less any colorant added to tint bases, and no person shall apply or solicit the application of any architectural coating within the District that exceeds 250 grams of VOC per liter of coating as calculated in this paragraph.
- (2) Except as provided in paragraphs (c)(3), (c)(4), and designated coatings averaged under (c)(6), no person shall supply, sell, offer for sale, manufacture, blend, or repackage, for use within the District, any architectural coating listed in the Table of Standards which contains VOC (excluding any colorant added to tint bases) in excess of the corresponding VOC limit specified in the table, after the effective date specified, and no person shall apply or solicit the application of any architectural coating within the District that exceeds the VOC limit as specified in this paragraph. No person shall apply or solicit the application within the District of any industrial maintenance coatings, except anti-graffiti coatings, for residential use or for use in areas such as office space and meeting rooms of industrial, commercial or institutional facilities not exposed to such extreme environmental conditions described in the definition of industrial maintenance coatings; or of any rust-preventative coating for industrial use, unless such a rust preventative coating complies with the Industrial Maintenance Coating VOC limit specified in the Table of Standards.

FACILITY PERMIT TO OPERATE

UNIVERSITY OF CALIFORNIA, LOS ANGELES

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 7-13-2007]

TABLE OF STANDARDS VOC LIMITS

Grams of VOC Per Liter of Coating,
 Less Water and Less Exempt Compounds

COATING CATEGORY	Ceiling Limit*	Current Limit	Effective Date					
			1/1/03	1/1/04	1/1/05	7/1/06	7/1/07	7/1/08
Bond Breakers	350							
Clear Wood Finishes	350					275		
Varnish	350					275		
Sanding Sealers	350					275		
Lacquer	680	550			275			
Clear Brushing Lacquer	680				275			
Concrete-Curing Compounds	350						100	
Concrete-Curing Compounds For Roadways and Bridges**	350							
Dry-Fog Coatings	400						150	
Fire-Proofing Exterior Coatings	450	350						
Fire-Retardant Coatings***								
Clear	650							
Pigmented	350							
Flats	250	100						50
Floor Coatings	420		100			50		
Graphic Arts (Sign) Coatings	500							
Industrial Maintenance (IM) Coatings	420			250		100		
High Temperature IM Coatings			420					
Zinc-Rich IM Primers	420		340			100		
Japans/Faux Finishing Coatings	700	350						
Magnesite Cement Coatings	600	450						
Mastic Coatings	300							
Metallic Pigmented Coatings	500							
Multi-Color Coatings	420	250						
Nonflat Coatings	250		150			50		
Nonflat High Gloss	250		150				50	

FACILITY PERMIT TO OPERATE

UNIVERSITY OF CALIFORNIA, LOS ANGELES

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 7-13-2007]

COATING CATEGORY	Ceiling Limit*	Current Limit	Effective Date					
			1/1/03	1/1/04	1/1/05	7/1/06	7/1/07	7/1/08
Pigmented Lacquer	680	550			275			
Pre-Treatment Wash Primers	780		420					
Primers, Sealers, and Undercoaters	350		200			100		
Quick-Dry Enamels	400		250			150	50	
Quick-Dry Primers, Sealers, and Undercoaters	350		200			100		
Recycled Coatings			250					
Roof Coatings	300		250		50			
Roof Coatings, Aluminum	500				100			
Roof Primers, Bituminous	350		350					
Rust Preventative Coatings	420		400			100		
Shellac								
Clear	730							
Pigmented	550							
Specialty Primers	350					250	100	
Stains	350		250				100	
Stains, Interior	250							
Swimming Pool Coatings								
Repair	650		340					
Other	340							
Traffic Coatings	250	150					100	
Waterproofing Sealers	400		250			100		
Waterproofing Concrete/Masonry Sealers	400					100		
Wood Preservatives								
Below-Ground	350							
Other	350							

* The specified limits remain in effect unless revised limits are listed in subsequent columns in the Table of Standards.

** Does not include compounds used for curbs and gutters, sidewalks, islands, driveways and other miscellaneous concrete areas.

*** The Fire-Retardant Coating category will be eliminated on January 1, 2007 and subsumed by the coating category for which they are formulated.

FACILITY PERMIT TO OPERATE
UNIVERSITY OF CALIFORNIA, LOS ANGELES

APPENDIX B: RULE EMISSION LIMITS
[RULE 1113 7-13-2007]

TABLE OF STANDARDS (cont.)
VOC LIMITS

Grams of VOC Per Liter of Material

COATING	Limit
Low-Solids Coating	120

FACILITY PERMIT TO OPERATE

UNIVERSITY OF CALIFORNIA, LOS ANGELES

APPENDIX B: RULE EMISSION LIMITS [RULE 1130 10-8-1999]

Except as otherwise provided in Rule 1130

(1) VOC Content of Graphic Arts Materials

The operator shall not apply any graphic arts material, including any VOC-containing materials added to the original graphic arts materials, which contains a total VOC in excess of the limits specified below:

<u>GRAPHIC ARTS MATERIAL</u>	VOC LIMIT	
	Grams per Liter of	
	Coating (or Ink or Adhesive), Less Water and Less Exempt Compounds	
	<u>(October 8, 1999)</u>	<u>Effective January 1, 2000</u>
Lithographic Ink	300	300
Letterpress Ink	300	300
Gravure Ink	300	300
Flexographic Ink Non-Porous Substrate	300	300
Flexographic Ink Porous Substrate	300	225
Flexographic Fluorescent Ink	300	300
Coating	300	300
Adhesive	300	150

(2) VOC Content of Fountain Solution

Through December 31, 1999, the operator shall not apply in any graphic arts operation any fountain solution, including any VOC-containing materials added to the original fountain solution, which contains a total VOC in excess

FACILITY PERMIT TO OPERATE
UNIVERSITY OF CALIFORNIA, LOS ANGELES

APPENDIX B: RULE EMISSION LIMITS
[RULE 1130 10-8-1999]

of 100 grams per liter of material. Effective January 1, 2000, the VOC content of fountain solution, including any VOC containing material added to the original fountain solution as applied, shall be:

- (A) no greater than 80 grams per liter of material, or
- (B) no greater than 100 grams per liter of material, if a refrigerated chiller is used.

FACILITY PERMIT TO OPERATE

UNIVERSITY OF CALIFORNIA, LOS ANGELES

APPENDIX B: RULE EMISSION LIMITS [RULE 1130.1 12-13-1996]

Except as otherwise provided in Rule 1130.1

(1) VOC Content of Screen Printing Materials

The operator shall not apply to any substrate any screen printing material, excluding extreme performance screen printing materials, which contains, as applied, a total amount of VOC in excess of the limits specified in subparagraphs (1)(A), (1)(B), or (1)(C). The applicable VOC limit for a screen printing operation shall be determined by first looking for the product in subparagraph (1)(A). If the product is not listed in subparagraph (1)(A), look for the product's substrate in subparagraph (1)(B). If the substrate is not listed in subparagraph (1)(B), look for the applicable limit in subparagraph (1)(C).

In lieu of meeting the requirements in subparagraph (1)(C), the operator may comply with the requirements in paragraph (2) if the screen printing material qualifies for an extreme performance classification under subdivision (e) of Rule 1130.1.

(A) For screen printing coatings and inks used in the production of the following products:

<u>PRODUCT</u>	<u>VOC LIMIT</u> grams per Liter of Coating (or Ink), Less water and Less Exempt Compounds	
	On and After December 13, 1996	
	<u>g/L</u>	<u>lbs/gal</u>
Chlorine Indicator	500	4.2
Containers	800	6.7
Electronic Circuit	850	7.1
Mechanically-Formed Products	800	6.7
Overlays	800	6.7
Polyethylene Products	800	6.7
Stained Glass Overlay	800	6.7
Sterilization Indicator	600	5.0
Sub-Printed Products	800	6.7
Water Slide Decals:		

FACILITY PERMIT TO OPERATE

UNIVERSITY OF CALIFORNIA, LOS ANGELES

APPENDIX B: RULE EMISSION LIMITS [RULE 1130.1 12-13-1996]

<u>PRODUCT</u>	<u>VOC LIMIT</u> grams per Liter of Coating (or Ink), Less water and Less Exempt Compounds	
Opaque Inks	800	6.7
Clear Inks	800	6.7
Ceramic Decal Inks	800	6.7

- (B) For screen printing coatings and inks not regulated by subparagraph (1)(A) and which are applied to the following specified substrates:

<u>SUBSTRATE</u>	<u>VOC LIMIT</u> grams per Liter of Coating (or Ink), Less water and Less Exempt Compounds	
	On and After December 13, 1996	
	<u>g/L</u>	<u>lbs/gal</u>
Ceramic	800	6.7
Fiberglass	600	5.0
Glass or Metal	600	5.0
Man-Made Textile	800	6.7
Unsealed Aluminum	800	6.7

If a substrate is regulated under more than one substrate category listed in subparagraph (1)(B), the category with the highest VOC limit shall apply.

- (C) For screen printing materials not regulated by the provisions in subparagraph (1)(A) or (1)(B), which have the following material classifications:

<u>SCREEN PRINTING MATERIAL</u>	<u>VOC LIMIT</u> grams per Liter of Coating (or Ink or Adhesive), Less water and Less Exempt Compounds
---------------------------------	--

FACILITY PERMIT TO OPERATE

UNIVERSITY OF CALIFORNIA, LOS ANGELES

APPENDIX B: RULE EMISSION LIMITS [RULE 1130.1 12-13-1996]

	On and After December 13, 1996	
	<u>g/L</u>	<u>lbs/gal</u>
Adhesive	400	3.3
Coating	400	3.3
Fine Detail Loose-leaf Binder Ink	745	6.2
Fluorescent Ink	540	4.5
High-VOC Serigraph Ink	800	6.7
Loose-leaf Binder Metallic Ink	745	6.2
Metallic Ink	400	3.3
Printing Ink	400	3.3
Resists	600	5.0
Scratch-Off Ink	800	6.7
Water-Slide Decal Adhesive	800	6.7

If a screen printing material is regulated under more than one screen printing material category listed in subparagraph (1)(C), the category with the highest VOC limit shall apply.

(2) **VOC Content of Extreme Performance Screen Printing Materials**

The operator shall not apply any extreme performance screen printing material in excess of the limits specified below:

	VOC LIMIT Grams of VOC per Liter of Extreme Performance Screen Printing Material, Less Water and <u>Less</u> <u>Exempt Compounds</u>	
	<u>g/L</u>	<u>lbs/gal</u>
On and after July 9, 1993	800	6.7
On and after January 1, 2003	400	3.3

(3) **Usage of High-VOC Serigraph Inks**

The total usage of high-VOC serigraph inks, as defined in paragraph (b)(23) of Rule 1130.1, shall not exceed 10 percent, (by volume), of the total usage of screen

FACILITY PERMIT TO OPERATE
UNIVERSITY OF CALIFORNIA, LOS ANGELES

APPENDIX B: RULE EMISSION LIMITS
[RULE 1130.1 12-13-1996]

printing materials applied on all serigraphs at a facility, on a monthly basis, unless an approved emission control system is used to reduce emissions from high-VOC serigraph inks by an equivalent or greater level to that which would have been achieved by the use of an ink containing 3.3 pounds per gallon VOC (less water and exempt compounds). The required overall control efficiency of the emission control system shall be determined by the equation in paragraph (d)(1) of Rule 1130.1.

FACILITY PERMIT TO OPERATE

UNIVERSITY OF CALIFORNIA, LOS ANGELES

APPENDIX B: RULE EMISSION LIMITS [RULE 1136 6-14-1996]

Except as otherwise provided in Rule 1136

- (a) The operator shall not apply any coating to a wood product which has a VOC content, including any VOC-containing material added to the original coating supplied by the manufacturer, which exceeds the applicable limit specified below:

<u>COATING</u>	VOC LIMITS Grams Per Liter (lb/gal) of Coating, [lbs VOC/lb of solids], <u>Less Water and Less Exempt Compounds</u>		
	<u>Current Limit</u>		<u>On and After</u> <u>7/1/2005</u>
	I	or II	
Clear Sealers	550 (4.6) [1.39]	680 (5.7) [3.36]	275 (2.3) [0.36]
Clear Topcoat	550 (4.6) [1.37]	275 (2.3) [0.35]	275 (2.3) [0.35]
Pigmented Primers, Sealers & Undercoats	550 (4.6) [1.06]	600 (5.0) [1.08]	275 (2.3) [0.21]
Pigmented Topcoats	550 (4.6) [1.10]	275 (2.3) [0.25]	275 (2.3) [0.25]

The operator shall use coatings on a wood product that comply with either all VOC limits in column I or all VOC limits in column II. The operator that applies a primer, sealer or undercoat, but not a topcoat, to a wood product, shall be subject to column I for that wood product.

- (2) Notwithstanding the requirements of clause (a)(1), an operator that applies a topcoat and a primer, sealer or undercoat to a shutter may, until July 1, 2005, choose to comply with the VOC limits specified below for that shutter:

VOC LIMITS Grams Per Liter, (lb/gal) of Coating, [lbs VOC/lb of solids], <u>Less Water and Less Exempt Compounds</u>	
<u>COATING</u>	
Clear Sealers	275 (2.3) [0.36]
Clear Topcoat	680 (5.7) [2.99]
Pigmented Primers, Sealers & Undercoats	275 (2.3) [0.33]
Pigmented Topcoats	600 (5.0) [1.38]

FACILITY PERMIT TO OPERATE

UNIVERSITY OF CALIFORNIA, LOS ANGELES

APPENDIX B: RULE EMISSION LIMITS [RULE 1136 6-14-1996]

(3)

VOC LIMITS

Grams Per Liter, (lb/gal) of Coating, (lbs VOC/lb of solids),
Less Water and Less Exempt Compounds

<u>COATING</u>	<u>Current Limit</u>	<u>On and After</u>
		<u>7/1/2005</u>
Barrier Coat - Plastic Components	760 (6.3) [3.9]	275 (2.3) [0.28]
Composite Wood Edge Filler	550 (4.6) [1.15]	275 (2.3) [0.31]
Extreme Performance Coatings	420 (3.5) [0.51]	275 (2.3) [0.33]
Fillers	500 (4.2) [0.66]	275 (2.3) [0.18]
High-Solid Stains	550 (4.6) [1.23]	350 (2.9) [0.42]
Inks	500 (4.2) [0.96]	500 (4.2) [0.96]
Mold-Seal Coatings	750 (6.3) [4.2]	750 (6.3) [4.2]
Multi-Colored Coatings	685 (5.7) [2.6]	275 (2.3) [0.33]

VOC LIMITS

Grams Per Liter (lb/gal) of Material

<u>COATING</u>	<u>Current Limit</u>	<u>On and After</u>
		<u>7/1/2005</u>
Low-Solids Barrier Coat - Plastic Components	760 (6.3)	120 (1.0)
Low-Solid Stains, Toners, and Washcoats	480 (4.0)	120 (1.0)

Any coating subject to this rule that meets any of the three VOC limit formats (grams per liter, lb/gal, or lbs VOC/lb of solids) is in compliance with this subparagraph.

- (4) The VOC limit for japan coatings is 700 grams per liter of coatings, less water and exempt compounds, as applied.
- (b) A person shall not use a stripper on wood products unless:
 - (1) it contains less than 350 grams of VOC per liter of material; or
 - (2) the VOC composite vapor pressure is 2 mm Hg (0.04 psia) or less at 20°C (68°F).

FACILITY PERMIT TO OPERATE

UNIVERSITY OF CALIFORNIA, LOS ANGELES

APPENDIX B: RULE EMISSION LIMITS **[RULE 1140 2-1-1980]**

- (1) The operator shall not, if he complies with an applicable performance standard in section (b)(4) of Rule 1140, discharge into the atmosphere from any abrasive blasting any air contaminant for a period or periods aggregating more than three minutes in any one hour which is:
 - (A) As dark or darker in shade as that designated as No. 2 on the Ringelmann Chart, as published by the United States Bureau of Mines,
or
 - (B) Of such opacity as to obscure an observer's view to a degree equal to or greater than does smoke described in (1)(A).
- (2) The operator shall not, if he is not complying with an applicable performance standard in section (b)(4) of Rule 1140, discharge into the atmosphere from any abrasive blasting any air contaminant for a period or periods aggregating more than three minutes in any one hour which is:
 - (A) As dark or darker in shade as that designated as No. 1 on the Ringelmann Chart, as published by the United States Bureau of Mines,
or
 - (B) Of such opacity as to obscure an observer's view to a degree equal to or greater than does smoke described in (2)(A).

FACILITY PERMIT TO OPERATE

UNIVERSITY OF CALIFORNIA, LOS ANGELES

APPENDIX B: RULE EMISSION LIMITS **[RULE 1140 8-2-1985]**

- (1) The operator shall not, if he complies with an applicable performance standard in section (b)(4) of Rule 1140, discharge into the atmosphere from any abrasive blasting any air contaminant for a period or periods aggregating more than three minutes in any one hour which is:
 - (A) As dark or darker in shade as that designated as No. 2 on the Ringelmann Chart, as published by the United States Bureau of Mines,
or
 - (B) Of such opacity as to obscure an observer's view to a degree equal to or greater than does smoke described in (1)(A).
- (2) The operator shall not, if he is not complying with an applicable performance standard in section (b)(4) of Rule 1140, discharge into the atmosphere from any abrasive blasting any air contaminant for a period or periods aggregating more than three minutes in any one hour which is:
 - (A) As dark or darker in shade as that designated as No. 1 on the Ringelmann Chart, as published by the United States Bureau of Mines,
or
 - (B) Of such opacity as to obscure an observer's view to a degree equal to or greater than does smoke described in (2)(A).

FACILITY PERMIT TO OPERATE

UNIVERSITY OF CALIFORNIA, LOS ANGELES

APPENDIX B: RULE EMISSION LIMITS [RULE 1145 12-3-2004]

A person shall not apply on plastics, glass, leather, or rubber any coatings which are applied with a VOC content in excess of the limits specified below:

COATING CATEGORIES	VOC Limits Less Water and Less Exempt Compounds Effective Dates									
	Current		Jan 1, 2005		Jan 1, 2006		Jan 1, 2007		Jan 1, 2008	
	g/L	lbs/gal	g/L	lbs/gal	g/L	lbs/gal	g/L	lbs/gal	g/L	lbs/gal
Electrical dissipating and shock free coatings	360	3.0								
Extreme performance two-component coatings	NA		NA		420	3.5				
General one-component coatings	275	2.3					120	1.0		
General two-component coatings	420	3.5			300	2.5			120	1.0
Leather antique coatings			156	1.3						
Leather color coatings			60	0.5						
Leather sealer coatings			60	0.5						
Leather stain coatings			216	1.8						
Leather top coatings			120	1.0						
Metallic coatings	420	3.5								
Military specification one-component coatings	340	2.8								
Military specification two-component coatings	420	3.5								
Mirror backing curtain coated coatings	500	4.2								
Mirror backing rolled coated coatings	430	3.6					312	2.6		
Mold seal coatings	750	6.3								
Multi-colored coatings	685	5.7								
Optical coatings	800	6.7					50	0.4		
Vacuum metalizing coatings	800	6.7								

FACILITY PERMIT TO OPERATE

UNIVERSITY OF CALIFORNIA, LOS ANGELES

APPENDIX B: RULE EMISSION LIMITS [RULE 1145 2-14-1997]

Except as otherwise provided in Rule 1145, the operator shall not apply on plastics, glass, or rubber any coatings which are applied with a VOC content in excess of the limits specified below:

COATING

	VOC LIMITS			
	<u>Less Water and Less Exempt</u>			
	<u>Compounds</u>			
	<u>Current</u>		<u>On and After 1-1-98</u>	
	<u>g/L</u>	<u>lbs/gal</u>	<u>g/L</u>	<u>lbs/gal</u>
General Coatings				
One-component	275	2.3	275	2.3
Two-component	420	3.5	420	3.5
Military Spec. Coating				
One-component	340	2.8	340	2.8
Two-component	420	3.5	420	3.5
Multi-Colored Coatings	685	5.7	685	5.7
Mold Seal Coatings	750	6.3	750	6.3
Vacuum Metalizing Coatings	800	6.7	800	6.7
Mirror Backing				
Curtain Coated	500	4.2	500	4.2
Roll Coated	430	3.6	430	3.6
Optical Coatings	800	6.7	800	6.7
Electric Dissipating Coatings and Shock-Free Coatings	800	6.7	360	3.0
Metallic Coatings	420	3.5	420	3.5

FACILITY PERMIT TO OPERATE

UNIVERSITY OF CALIFORNIA, LOS ANGELES

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 11-7-2003]

(1) Solvent Requirements

A person shall not use a solvent to perform solvent cleaning operations unless the solvent complies with the applicable requirements set forth below:

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS
	VOC g/l (lb/gal)
(A) Product Cleaning During Manufacturing Process Or Surface Preparation For Coating, Adhesive, Or Ink Application	
(i) General	25 (0.21)
(ii) Electrical Apparatus Components & Electronic Components	500 (4.2)
(iii) Medical Devices & Pharmaceuticals	800 (6.7)
(B) Repair and Maintenance Cleaning	
(i) General	25 (0.21)
(ii) Electrical Apparatus Components & Electronic Components	900 (7.5)
(iii) Medical Devices & Pharmaceuticals	
(A) Tools, Equipment, & Machinery	800 (6.7)
(B) General Work Surfaces	600 (5.0)

FACILITY PERMIT TO OPERATE

UNIVERSITY OF CALIFORNIA, LOS ANGELES

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 11-7-2003]

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS
	VOC g/l (lb/gal)
(C) Cleaning of Coatings or Adhesives Application Equipment	550 (4.6)
(D) Cleaning of Ink Application Equipment	
(i) General	25 (0.21)
(ii) Flexographic Printing	25 (0.21)
(iii) Gravure Printing	
(A) Publication	750 (6.3)
(B) Packaging	25 (0.21)
(iv) Lithographic or Letter Press Printing	
(A) Roller Wash – Step 1	600 (5.0)
(B) Roller Wash-Step 2, Blanket Wash, & On-Press Components	800 (6.7)
(C) Removable Press Components	25 (0.21)
(v) Screen Printing	750 (6.3)
(vi) Ultraviolet Ink/ Electron Beam Ink Application Equipment (except screen printing)	800 (6.7)

FACILITY PERMIT TO OPERATE
UNIVERSITY OF CALIFORNIA, LOS ANGELES

APPENDIX B: RULE EMISSION LIMITS
[RULE 1171 11-7-2003]

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS
	VOC g/l (lb/gal)
(vii) Specialty Flexographic Printing	600 (5.0)
(E) Cleaning of Polyester Resin Application Equipment	25 (0.21)

FACILITY PERMIT TO OPERATE

UNIVERSITY OF CALIFORNIA, LOS ANGELES

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 2-1-2008]

(I) Solvent Requirements

A person shall not use a solvent to perform solvent cleaning operations unless the solvent complies with the applicable requirements set forth below:

	CURRENT LIMITS*	EFFECTIVE 1/1/2008*	EFFECTIVE 1/1/2009
SOLVENT CLEANING ACTIVITY	VOC g/l (lb/gal)	VOC g/l (lb/gal)	VOC g/l (lb/gal)
(A) Product Cleaning During Manufacturing Process Or Surface Preparation For Coating, Adhesive, Or Ink Application			
(i) General	25 (0.21)		
(ii) Electrical Apparatus Components & Electronic Components	100 (0.83)		
(iii) Medical Devices & Pharmaceuticals	800 (6.7)		
(B) Repair and Maintenance Cleaning			
(i) General	25 (0.21)		
(ii) Electrical Apparatus Components & Electronic Components	100 (0.83)		

FACILITY PERMIT TO OPERATE

UNIVERSITY OF CALIFORNIA, LOS ANGELES

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 2-1-2008]

SOLVENT CLEANING ACTIVITY (cont.)	CURRENT LIMITS*	EFFECTIVE 1/1/2008*	EFFECTIVE 1/1/2009
	VOC g/l (lb/gal)	VOC g/l (lb/gal)	VOC g/l (lb/gal)
(iii) Medical Devices & Pharmaceuticals			
(A) Tools, Equipment, & Machinery	800 (6.7)		
(B) General Work Surfaces	600 (5.0)		
(C) Cleaning of Coatings or Adhesives Application Equipment	25 (0.21)		
(D) Cleaning of Ink Application Equipment			
(i) General	25 (0.21)		
(ii) Flexographic Printing	25 (0.21)		
(iii) Gravure Printing			
(A) Publication	100 (0.83)		
(B) Packaging	25 (0.21)		
(iv) Lithographic (Offset) or Letter Press Printing			
(A) Roller Wash, Blanket Wash, & On-Press Components			
(I) Newsprint	100 (0.83)		

FACILITY PERMIT TO OPERATE

UNIVERSITY OF CALIFORNIA, LOS ANGELES

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 2-1-2008]

	CURRENT LIMITS*	EFFECTIVE 1/1/2008*	EFFECTIVE 1/1/2009
SOLVENT CLEANING ACTIVITY (cont.)	VOC g/l (lb/gal)	VOC g/l (lb/gal)	VOC g/l (lb/gal)
(II) Other Substrates	500 (4.2)	100 (0.83)	
(B) Removable Press Components	25 (0.21)		
(v) Screen Printing	500 (4.2)	100 (0.83)	
(vi) Ultraviolet Ink/ Electron Beam Ink Application Equipment (except screen printing)	650 (5.4)	650 (5.4)	100 (0.83)
(vii) Specialty Flexographic Printing	100 (0.83)		
(E) Cleaning of Polyester Resin Application Equipment	25 (0.21)		

* The specified limits remain in effect unless revised limits are listed in subsequent columns.

FACILITY PERMIT TO OPERATE

UNIVERSITY OF CALIFORNIA, LOS ANGELES

APPENDIX B: RULE EMISSION LIMITS [RULE 404 2-7-1986]

The operator shall not discharge into the atmosphere from this equipment, particulate matter in excess of the concentration at standard conditions, shown in Table 404(a).

Where the volume discharged is between figures listed in the Table, the exact concentration permitted to be discharged shall be determined by linear interpolation.

For the purposes of this rule, emissions shall be averaged over one complete cycle of operation or one hour, whichever is the lesser time period.

TABLE 404(a)

Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions		Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions	
Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot	Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot
25 or less	883 or less	450	0.196	900	31780	118	0.0515
30	1059	420	.183	1000	35310	113	.0493
35	1236	397	.173	1100	38850	109	.0476
40	1413	377	.165	1200	42380	106	.0463
45	1589	361	.158	1300	45910	102	.0445
50	1766	347	.152	1400	49440	100	.0437
60	2119	324	.141	1500	52970	97	.0424
70	2472	306	.134	1750	61800	92	.0402

FACILITY PERMIT TO OPERATE

UNIVERSITY OF CALIFORNIA, LOS ANGELES

APPENDIX B: RULE EMISSION LIMITS [RULE 404 2-7-1986]

Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions		Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions	
Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot	Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot
80	2825	291	.127	2000	70630	87	.0380
90	3178	279	.122	2250	79460	83	.0362
100	3531	267	.117	2500	88290	80	.0349
125	4414	246	.107	3000	105900	75	.0327
150	5297	230	.100	4000	141300	67	.0293
175	6180	217	.0947	5000	176600	62	.0271
200	7063	206	.0900	6000	211900	58	.0253
250	8829	190	.0830	8000	282500	52	.0227
300	10590	177	.0773	10000	353100	48	.0210
350	12360	167	.0730	15000	529700	41	.0179
400	14130	159	.0694	20000	706300	37	.0162
450	15890	152	.0664	25000	882900	34	.0148
500	17660	146	.0637	30000	1059000	32	.0140
600	21190	137	.0598	40000	1413000	28	.0122
700	24720	129	.0563	50000	1766000	26	.0114
800	28250	123	.0537	70000 or more	2472000 or more	23	.0100

FACILITY PERMIT TO OPERATE UNIVERSITY OF CALIFORNIA, LOS ANGELES

APPENDIX B: RULE EMISSION LIMITS [RULE 405 2-7-1986]

The operator shall not discharge into the atmosphere from this equipment, solid particulate matter including lead and lead compounds in excess of the rate shown in Table 405(a).

Where the process weight per hour is between figures listed in the table, the exact weight of permitted discharge shall be determined by linear interpolation.

For the purposes of this rule, emissions shall be averaged over one complete cycle of operation or one hour, whichever is the lesser time period.

TABLE 405(a)

Process Weight Per Hour		Maximum Discharge Rate Allowed for Solid Particulate Matter (Aggregate Discharged From All Points of Process)		Process Weight Per Hour		Maximum Discharge Rate Allowed for Solid Particulate Matter (Aggregate Discharged From All points of Process)	
Kilograms Per Hour	Pounds Per Hour	Kilograms Per Hour	Pounds Per Hour	Kilograms Per Hour	Pounds Per Hour	Kilograms Per Hour	Pounds Per Hour
100 or less	220 or less	0.450	0.99	9000	19840	5.308	11.7
150	331	0.585	1.29	10000	22050	5.440	12.0
200	441	0.703	1.55	12500	27560	5.732	12.6
250	551	0.804	1.77	15000	33070	5.982	13.2
300	661	0.897	1.98	17500	38580	6.202	13.7
350	772	0.983	2.17	20000	44090	6.399	14.1
400	882	1.063	2.34	25000	55120	6.743	14.9
450	992	1.138	2.51	30000	66140	7.037	15.5
500	1102	1.209	2.67	35000	77160	7.296	16.1
600	1323	1.340	2.95	40000	88180	7.527	16.6
700	1543	1.461	3.22	45000	99210	7.738	17.1
800	1764	1.573	3.47	50000	110200	7.931	17.5
900	1984	1.678	3.70	60000	132300	8.277	18.2
1000	2205	1.777	3.92	70000	154300	8.582	18.9

FACILITY PERMIT TO OPERATE

UNIVERSITY OF CALIFORNIA, LOS ANGELES

APPENDIX B: RULE EMISSION LIMITS [RULE 405 2-7-1986]

Process Weight Per Hour		Maximum Discharge Rate Allowed for Solid Particulate Matter (Aggregate Discharged From All Points of Process)		Process Weight Per Hour		Maximum Discharge Rate Allowed for Solid Particulate Matter (Aggregate Discharged From All points of Process)	
Kilograms Per Hour	Pounds Per Hour	Kilograms Per Hour	Pounds Per Hour	Kilograms Per Hour	Pounds Per Hour	Kilograms Per Hour	Pounds Per Hour
1250	2756	2.003	4.42	80000	176400	8.854	19.5
1500	3307	2.206	4.86	90000	198400	9.102	20.1
1750	3858	2.392	5.27	100000	220500	9.329	20.6
2000	4409	2.563	5.65	125000	275600	9.830	21.7
2250	4960	2.723	6.00	150000	330700	10.26	22.6
2500	5512	2.874	6.34	175000	385800	10.64	23.5
2750	6063	3.016	6.65	200000	440900	10.97	24.2
3000	6614	3.151	6.95	225000	496000	11.28	24.9
3250	7165	3.280	7.23	250000	551200	11.56	25.5
3600	7716	3.404	7.50	275000	606300	11.82	26.1
4000	8818	3.637	8.02	300000	661400	12.07	26.6
4500	9921	3.855	8.50	325000	716500	12.30	27.1
5000	11020	4.059	8.95	350000	771600	12.51	27.6
6000	13230	4.434	9.78	400000	881800	12.91	28.5
7000	15430	4.775	10.5	450000	992100	13.27	29.3
8000	17640	5.089	11.2	500000 or more	1102000 or more	13.60	30.0

FACILITY PERMIT TO OPERATE UNIVERSITY OF CALIFORNIA, LOS ANGELES

SECTION K: TITLE V Administration

GENERAL PROVISIONS

1. This permit may be revised, revoked, reopened and reissued, or terminated for cause, or for failure to comply with regulatory requirements, permit terms, or conditions. [3004(a)(7)(C)]
2. This permit does not convey any property rights of any sort or any exclusive privilege. [3004(a)(7)(E)]

Permit Renewal and Expiration

3. (A) Except for solid waste incineration facilities subject to standards under Section 129(e) of the Clean Air Act, this permit shall expire five years from the date that this Title V permit is issued. The operator's right to operate under this permit terminates at midnight on this date, unless the facility is protected by an application shield in accordance with Rule 3002(b), due to the filing of a timely and complete application for a Title V permit renewal, consistent with Rule 3003. [3004(a)(2), 3004(f)]

(B) A Title V permit for a solid waste incineration facility combusting municipal waste subject to standards under Section 129(e) of the Clean Air Act shall expire 12 years from the date of issuance unless such permit has been renewed pursuant to this regulation. These permits shall be reviewed by the Executive Officer at least every five years from the date of issuance. [3004(f)(2)]
4. To renew this permit, the operator shall submit to the Executive Officer an application for renewal at least 180 days, but not more than 545 days, prior to the expiration date of this permit. [3003(a)(6)]

Duty to Provide Information

5. The applicant for, or holder of, a Title V permit shall furnish, pursuant to Rule 3002(d) and (e), timely information and records to the Executive Officer or designee within a reasonable time as specified in writing by the Executive Officer or designee. [3004(a)(7)(F)]

Payment of Fees

6. The operator shall pay all required fees specified in Regulation III - Fees. [3004(a)(7)(G)]

Reopening for Cause

7. The Executive Officer will reopen and revise this permit if any of the following circumstances occur:

(A) Additional regulatory requirements become applicable with a remaining permit term of three or more years. Reopening is not required if the effective date of the requirement is later than the expiration date of this permit, unless the permit or any of its terms and conditions has been extended pursuant to paragraph (f)(4) of Rule 3004.

FACILITY PERMIT TO OPERATE UNIVERSITY OF CALIFORNIA, LOS ANGELES

SECTION K: TITLE V Administration

- (B) The Executive Officer or EPA Administrator determines that this permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of this permit.
- (C) The Executive Officer or EPA Administrator determines that the permit must be revised or revoked to assure compliance with the applicable requirements. [3005(g)(1)]

COMPLIANCE PROVISIONS

8. The operator shall comply with all regulatory requirements, and all permit terms and conditions, except:
- (A) As provided for by the emergency provisions of condition no. 17 or condition no. 18, or

- (B) As provided by an alternative operating condition granted pursuant to a federally approved (SIP-approved) Rule 518.2.

Any non-compliance with any federally enforceable permit condition constitutes a violation of the Federal Clean Air Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or revision; or denial of a permit renewal application. Non-compliance may also be grounds for civil or criminal penalties under the California State Health and Safety Code. [3004(a)(7)(A)]

9. The operator shall allow the Executive Officer or authorized representative, upon presentation of appropriate credentials to:
- (A) Enter the operator's premises where emission-related activities are conducted, or records are kept under the conditions of this permit;
 - (B) Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;
 - (C) Inspect at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit; and
 - (D) Sample or monitor at reasonable times, substances or parameters for the purpose of assuring compliance with the facility permit or regulatory requirements. [3004(a)(10)(B)]
10. All terms and conditions in this permit, including any provisions designed to limit a facility's potential to emit, are enforceable by the EPA Administrator and citizens under the federal Clean Air Act, unless the term or condition is designated as not federally enforceable. Each day during any portion of which a violation occurs is a separate offense. [3004(g)]

FACILITY PERMIT TO OPERATE UNIVERSITY OF CALIFORNIA, LOS ANGELES

SECTION K: TITLE V Administration

11. A challenge to any permit condition or requirement raised by EPA, the operator, or any other person, shall not invalidate or otherwise affect the remaining portions of this permit. [3007(b)]
12. The filing of any application for a permit revision, revocation, or termination, or a notification of planned changes or anticipated non-compliance does not stay any permit condition. [3004(a)(7)(D)]
13. It shall not be a defense for a person in an enforcement action, including those listed in Rule 3002(c)(2), that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit; except as provided for in "Emergency Provisions" of this section. [3004(a)(7)(H)]
14. The operator shall not build, erect, install, or use any equipment, the use of which, without resulting in a reduction in the total release of air contaminants to atmosphere, reduces or conceals an emission which would otherwise constitute a violation of Chapter 3 (commencing with Section 41700) of Part 4, of Division 26 of the California Health and Safety Code or of AQMD rules. This rule shall not apply to cases in which the only violation involved is of Section 41700 of the California Health and Safety Code, or Rule 402 of AQMD Rules. [408]
15. Nothing in this permit or in any permit shield can alter or affect:
 - (A) Under Section 303 of the federal Clean Air Act, the provisions for emergency orders;
 - (B) The liability of the operator for any violation of applicable requirements prior to or at the time of permit issuance;
 - (C) The applicable requirements of the Acid Rain Program, Regulation XXXI;
 - (D) The ability of EPA to obtain information from the operator pursuant to Section 114 of the federal Clean Air Act;
 - (E) The applicability of state or local requirements that are not "applicable requirements", as defined in Rule 3000, at the time of permit issuance but which do apply to the facility, such as toxics requirements unique to the State; and
 - (F) The applicability of regulatory requirements with compliance dates after the permit issuance date. [3004(c)(3)]
16. For any portable equipment that requires an AQMD or state permit or registration, excluding a) portable engines, b) military tactical support equipment and c) AQMD-permitted portable equipment that are not a major source, are not located at the facility for more than 12 consecutive months after

FACILITY PERMIT TO OPERATE UNIVERSITY OF CALIFORNIA, LOS ANGELES

SECTION K: TITLE V Administration

commencing operation, and whose operation does not conflict with the terms or conditions of this Title V permit: 1) the facility operator shall keep a copy of the AQMD or state permit or registration; 2) the equipment operator shall comply with the conditions on the permit or registration and all other regulatory requirements; and 3) the facility operator shall treat the permit or registration as a part of its Title V permit, subject to recordkeeping, reporting and certification requirements. [3004(a)(1)]

FACILITY PERMIT TO OPERATE UNIVERSITY OF CALIFORNIA, LOS ANGELES

SECTION K: TITLE V Administration

EMERGENCY PROVISIONS

17. An emergency¹ constitutes an affirmative defense to an action brought for non-compliance with a technology-based emission limit only if:
- (A) Properly signed, contemporaneous operating records or other credible evidence demonstrate that:
 - (1) An emergency occurred and the operator can identify the cause(s) of the emergency;
 - (2) The facility was operated properly (i.e. operated and maintained in accordance with the manufacturer's specifications, and in compliance with all regulatory requirements or a compliance plan), before the emergency occurred;
 - (3) The operator took all reasonable steps to minimize levels of emissions that exceeded emissions standard, or other requirements in the permit; and,
 - (4) The operator submitted a written notice of the emergency to the AQMD within two working days of the time when the emissions limitations were exceeded due to the emergency. The notice shall contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken; and
 - (B) The operator complies with the breakdown provisions of Rule 430 - Breakdown Provisions, or subdivision (i) of Rule 2004 - Requirements, whichever is applicable. [3002(g), 430, 2004(i)]
18. The operator is excused from complying with any regulatory requirement that is suspended by the Executive Officer during a state of emergency or state of war emergency, in accordance with Rule 118 - Emergencies. [118]

¹ "Emergency" means any situation arising from sudden and reasonably unforeseeable events beyond the control of the operator, including acts of God, which: (A) requires immediate corrective action to restore normal operation; and (B) causes the facility to exceed a technology-based emission limitation under the permit, due to unavoidable increases in emissions attributable to the emergency; and (C) is not caused by improperly designed equipment, lack of preventative maintenance, careless or improper operation, or operator error.

FACILITY PERMIT TO OPERATE UNIVERSITY OF CALIFORNIA, LOS ANGELES

SECTION K: TITLE V Administration

RECORDKEEPING PROVISIONS

19. In addition to any other recordkeeping requirements specified elsewhere in this permit, the operator shall keep records of required monitoring information, where applicable, that include:
 - (A) The date, place as defined in the Title V permit, and time of sampling or measurements;
 - (B) The date(s) analyses were performed;
 - (C) The company or entity that performed the analyses;
 - (D) The analytical techniques or methods used;
 - (E) The results of such analyses; and
 - (F) The operating conditions as existing at the time of sampling or measurement. [3004(a)(4)(B)]
20. The operator shall maintain records pursuant to Rule 109 and any applicable material safety data sheet (MSDS) for any equipment claimed to be exempt from a written permit by Rule 219 based on the information in those records. [219(t)]
21. The operator shall keep all records of monitoring data required by this permit or by regulatory requirements for a period of at least five years from the date of the monitoring sample, measurement, report, or application. [3004(a)(4)(E)]

REPORTING PROVISIONS

22. The operator shall comply with the following requirements for prompt reporting of deviations:
 - (A) Breakdowns shall be reported as required by Rule 430 - Breakdown Provisions or subdivision (i) of Rule 2004 - Requirements, whichever is applicable.
 - (B) Other deviations from permit or applicable rule emission limitations, equipment operating conditions, or work practice standards, determined by observation or by any monitoring or testing required by the permit or applicable rules that result in emissions greater than those allowed by the permit or applicable rules shall be reported within 72 hours (unless a shorter reporting period is specified in an applicable State or Federal Regulation) of discovery of the deviation by contacting AQMD enforcement personnel assigned to this facility or otherwise calling (800) CUT-SMOG.

FACILITY PERMIT TO OPERATE UNIVERSITY OF CALIFORNIA, LOS ANGELES

SECTION K: TITLE V Administration

- (C) A written report of such deviations reported pursuant to (B), and any corrective actions or preventative measures taken, shall be submitted to AQMD, in an AQMD approved format, within 14 days of discovery of the deviation.
 - (D) All other deviations shall be reported with the monitoring report required by condition no. 23. [3004(a)(5)]
23. Unless more frequent reporting of monitoring results are specified in other permit conditions or in regulatory requirements, the operator shall submit reports of any required monitoring to the AQMD at least twice per year. The report shall include a) a statement whether all monitoring required by the permit was conducted; and b) identification of all instances of deviations from permit or regulatory requirements. A report for the first six calendar months of the year is due by August 31 and a report for the last six calendar months of the year is due by February 28. [3004(a)(4)(F)]
24. The operator shall submit to the Executive Officer and to the Environmental Protection Agency (EPA), an annual compliance certification. For RECLAIM facilities, the certification is due when the Annual Permit Emissions Program (APEP) report is due and shall cover the same reporting period. For other facilities, the certification is due on March 1 for the previous calendar year. The certification need not include the period preceding the date the initial Title V permit was issued. Each compliance certification shall include:
- (A) Identification of each permit term or condition that is the basis of the certification;
 - (B) The compliance status during the reporting period;
 - (C) Whether compliance was continuous or intermittent;
 - (D) The method(s) used to determine compliance over the reporting period and currently, and
 - (E) Any other facts specifically required by the Executive Officer to determine compliance.

The EPA copy of the certification shall be sent to: Director of the Air Division Attn: Air-3 USEPA, Region IX 75 Hawthorne St. San Francisco, CA 94105 [3004(a)(10)(E)]

25. All records, reports, and documents required to be submitted by a Title V operator to AQMD or EPA shall contain a certification of accuracy consistent with Rule 3003(c)(7) by a responsible official (as defined in Rule 3000). [3004(a)(12)]

FACILITY PERMIT TO OPERATE UNIVERSITY OF CALIFORNIA, LOS ANGELES

SECTION K: TITLE V Administration

PERIODIC MONITORING

26. All periodic monitoring required by this permit pursuant to Rule 3004(a)(4)(c) is based on the requirements and justifications in the AQMD document "Periodic Monitoring Guidelines for Title V Facilities" or in case-by-case determinations documented in the Title V application file. [3004(a)(4)]

FACILITY PERMIT TO OPERATE UNIVERSITY OF CALIFORNIA, LOS ANGELES

SECTION K: TITLE V Administration

FACILITY RULES

This facility is subject to the following rules and regulations:

With the exception of Rule 402, 473, 477, 1118 and Rules 1401 through 1420, the following rules that are designated as non-federally enforceable are pending EPA approval as part of the state implementation plan. Upon the effective date of that approval, the approved rule(s) will become federally enforceable, and any earlier versions of those rules will no longer be federally enforceable.

RULE SOURCE	Adopted/Amended Date	FEDERAL Enforceability
RULE 1107	1-6-2006	Non federally enforceable
RULE 1107	11-9-2001	Federally enforceable
RULE 1113	11-8-1996	Federally enforceable
RULE 1113	7-13-2007	Non federally enforceable
RULE 1130	10-8-1999	Federally enforceable
RULE 1130.1	12-13-1996	Federally enforceable
RULE 1134	8-8-1997	Federally enforceable
RULE 1136	6-14-1996	Federally enforceable
RULE 1140	2-1-1980	Federally enforceable
RULE 1140	8-2-1985	Non federally enforceable
RULE 1145	12-3-2004	Non federally enforceable
RULE 1145	2-14-1997	Federally enforceable
RULE 1146	11-17-2000	Federally enforceable
RULE 1146.1	5-13-1994	Federally enforceable
RULE 1146.2	1-7-2005	Non federally enforceable
RULE 1146.2	1-9-1998	Federally enforceable
RULE 1170	5-6-1988	Non federally enforceable
RULE 1171	11-7-2003	Federally enforceable
RULE 1171	2-1-2008	Non federally enforceable
RULE 1303(a)(1)-BACT	12-6-2002	Non federally enforceable
RULE 1303(a)(1)-BACT	5-10-1996	Federally enforceable
RULE 1303(b)(2)-Offset	12-6-2002	Non federally enforceable
RULE 1303(b)(2)-Offset	5-10-1996	Federally enforceable
RULE 1304(a)-Modeling and Offset Exemption	6-14-1996	Federally enforceable
RULE 1401	3-7-2008	Non federally enforceable
RULE 1403	10-5-2007	Non federally enforceable
RULE 1404	4-6-1990	Non federally enforceable
RULE 1415	10-14-1994	Non federally enforceable
RULE 1418	9-10-1999	Non federally enforceable

FACILITY PERMIT TO OPERATE UNIVERSITY OF CALIFORNIA, LOS ANGELES

SECTION K: TITLE V Administration

RULE SOURCE	Adopted/Amended Date	FEDERAL Enforceability
RULE 1470	6-1-2007	Non federally enforceable
RULE 204	10-8-1993	Federally enforceable
RULE 217	1-5-1990	Federally enforceable
RULE 218	5-14-1999	Non federally enforceable
RULE 218	8-7-1981	Federally enforceable
RULE 219	6-1-2007	Non federally enforceable
RULE 219	9-4-1981	Federally enforceable
RULE 3004	12-12-1997	Federally enforceable
RULE 3007	10-8-1993	Federally enforceable
RULE 304	6-9-2006	Non federally enforceable
RULE 402	5-7-1976	Non federally enforceable
RULE 404	2-7-1986	Federally enforceable
RULE 405	2-7-1986	Federally enforceable
RULE 407	4-2-1982	Federally enforceable
RULE 408	5-7-1976	Federally enforceable
RULE 409	8-7-1981	Federally enforceable
RULE 429	12-21-1990	Non federally enforceable
RULE 430	7-12-1996	Non federally enforceable
RULE 431.1	6-12-1998	Federally enforceable
RULE 431.2	5-4-1990	Federally enforceable
RULE 431.2	9-15-2000	Non federally enforceable
RULE 461	3-7-2008	Federally enforceable
RULE 475	10-8-1976	Federally enforceable
RULE 475	8-7-1978	Non federally enforceable
RULE 476	10-8-1976	Federally enforceable
RULE 481	1-11-2002	Federally enforceable
40CFR 60 Subpart GG	2-24-2006	Federally enforceable
RULE 701	6-13-1997	Federally enforceable
40CFR 82 Subpart B	7-14-1992	Federally enforceable
40CFR 82 Subpart F	5-14-1993	Federally enforceable